LGAI Technological Center, S.A. (APPLUS)
Campus UAB - Ronda de la Font del Carme s/n
08193 Bellaterra (Barcelona)
T +34 93 567 20 00
www.applus.com





Notified Body No. 0370

# **CERTIFICATE**



No

0370-CPR-3913

#### CERTIFICATE OF CONSTANCY OF PERFORMANCE

In compliance with Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product:

POWER, CONTROL AND COMMUNICATION CABLES. CABLES FOR GENERAL APPLICATIONS IN CONSTRUCTION WORKS SUBJECT TO REACTION TO FIRE REQUIREMENTS.

FAMILY: Z1C4Z1-K/HSLCH/LIHCH (300/500V) CLASSIFICATION: Cca-s1b,d1,a1

Place on the market under the name of:

## CABLETEL DISTRIBUCIONES IBERIA, S.L.

C/ AHORRO, 19 - POL. IND. CTRA. AMARILLA 41007 SEVILLA (SPAIN)

And produced in the manufacturing plant:

#### 19/32301715

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard

EN 50575:2014, EN 50575:2014/A1:2016

under system 1+ are applied and that the product fulfils all the prescribed requirements set out above.

This certificate was first issued on 13<sup>th</sup> March 2020 and will remain valid as long as the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly.

The monitoring assessment will be done before December 2020

Bellaterra, 13th March 2020

Applus LGAI Technological Center, S.A.

Xavier Ruiz Peña

Managing Director, Product Conformity B.U.

This document is not valid without its technical annex; whose number coincides with the number of certificate.

You can check the validity of this certificate into our website at: <a href="https://apps.applus.com/microsites/microsites/FECIP/login">https://apps.applus.com/microsites/microsites/FECIP/login</a>



LGAI Technological Center, S.A. (APPLUS) Campus UAB s/n – Ronda de la Font del Carme, s/n E - 08193 Bellaterra (Barcelona) T +34 93 567 20 00 www.appluslaboratories.com



Technical Annex Ed. 1 13/03/2020

### 0370-CPR-3913

DESIGNATION	Z1C4Z1-K/HSLCH/LIHCH (300/500V)
REACTION TO FIRE CLASS	Cca-s1b,d1,a1

CROSS SECTIONAL RANGE	RATED VOLTAGE
0,22 mm² (N° Conductors: 2,3,4,5,6,7,8,12,25); 0,34 mm² (N° Conductors: 2,3,4,8,22,40); 0,5 mm² (N° Conductors: 2,3,4,5,6,8,10,12,16, 20,24, 25, 30, 32); 0,75 mm² (N° Conductors: 2,3,4,6,7,8,10,12,16,18,20); 1 mm² (N° Conductors: 2, 3, 4, 5, 6, 7, 8, 10, 12, 14, 16, 19, 20, 24, 25, 26, 27, 28, 30, 31, 36, 37, 40, 44); 1,5 mm² (N° Conductors: 2, 3, 4, 5, 6, 7, 8, 10, 12, 14, 16, 18, 20, 24, 25, 28, 34, 37); 2,5 mm² (N° Conductors: 2, 3, 4, 5, 6, 7, 8, 10, 12, 14, 16, 19, 20, 24, 25); 4 mm² (N° Conductors: 2,3,4,5); 6 mm² (N° Conductors: 2,3,4,5); 6 mm² (N° Conductors: 2,4,5); 4x0,14 mm²; 4x10 mm²; 4x16 mm².	300/500 V